

# ELECTRICAL INSTALLATION CONDITION REPORT

MD5126 - Master



Lister Electrical Ltd: 01904 798649

<b>A. Details of the Client/Person Ordering the Report</b>		<b>B. Reason for Producing this Report</b>	
Client:	SIMPSON PROPERTIES	Purpose of this report:	CLIENTS REQUEST
Address:	THE CATALYST BAIRD LANE YORK NORTH YORKSHIRE YO10 5GA	Date(s) on which Inspection: and testing was carried out	08/06/2021
<b>C. Details of the Installation which is the Subject of this Report</b>		Domestic <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Industrial <input type="checkbox"/>	
Installation:	33 ABBOTSFORD ROAD	Description of premises:	<input checked="" type="checkbox"/> <input type="checkbox"/> N/A <input type="checkbox"/> N/A
Occupier:	Occupier	Other:	N/A
Address:	LAYERTHORPE YORK NORTH YORKSHIRE YO10 3EE	Estimated age of wiring system:	40 yrs
Record of Installation available:	N/A	Records held By:	N/A
		Evidence of alterations or additions:	<input checked="" type="checkbox"/> <input type="checkbox"/> If yes estimated Age <input type="checkbox"/> <10 yrs
		Date of previous inspection:	Not Known
<b>D. Extent and Limitations Inspection and Testing</b>		Agreed limitations including the reasons (See regulation 653.2)	
Extent of Electrical Installation covered by this report: ..... --See Additional Page--		..... --See Additional Page--	
Operational Limitations including the reasons (See page No <input type="checkbox"/> N/A )		Agreed with name ANDY SIMPSON	
None			
This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS7671:2018 (IET Wiring Regulations) as amended to February 2020 It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.			
<b>E. Summary of the Condition of the Installation</b>		General condition of the installations (In terms of electrical safety)	
PLEASE REFER TO THE REPORT SIM/31397/D FOR THE CONDITION OF THE INSTALLATION. --See Additional Page--			
Overall assessment of the installation		Satisfactory	
*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.			
<b>F. Recommendations</b>			
Where the overall assessment of the suitability of the installation for continued use above is stated as SATISFACTORY, I recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (code FI). Observation classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken I recommend that the installation is further inspected and tested by 08/06/2026			
<b>G. Declaration</b>			
I, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by My signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.			
Trading Title and address	J. LISTER ELECTRICAL LTD, 2 BIRCH COURT, OSBALDWICK LINK ROAD, YORK, NORTH YORKSHIRE, YO19 5JA	NICEIC Enrolment Number	10012
		Branch No. (If Applicable)	N/A
<b>Inspected and tested by:</b>			
Name	PAUL NORFOLK	Position	APPROVED ELECTRIC
Signature		Date	23/07/2021
<b>Report authorised for issue by:</b>			
Name	MATTHEW GABBITAS	Position	QUALIFIED SUPERVIS
Signature		Date	23/07/2021
<b>H. Schedule(s)</b> The attached schedule(s) are part of this document and this report is valid only when they are attached to it.			
N/A		Schedule(s) of inspection and N/A	
Schedule(s) of test results are attached			

**I. Supply Characteristics and Earthing Arrangements**

Earthing Arrangements	Number and Type of Live Conductors				Nature of Supply Parameters			Supply protective device	
TN-S <input checked="" type="checkbox"/>	a.c. <input checked="" type="checkbox"/>			d.c. <input type="checkbox"/> N/A	Nominal Voltage $U^{(1)}$	N/A	V	BS(EN)	
TN-C-S <input type="checkbox"/> N/A	1-Phase (2 wire) <input checked="" type="checkbox"/>	1-Phase (3 wire) <input type="checkbox"/> N/A		2 Wire <input type="checkbox"/> N/A	Nominal Voltage $U_0^{(1)}$	230	V	LIM	
TN-C <input type="checkbox"/> N/A	2-Phase (3 wire) <input type="checkbox"/> N/A			3 Wire <input type="checkbox"/> N/A	Nominal frequency $f^{(1)}$	50	Hz	Type	
TT <input type="checkbox"/> N/A	3-Phase (3 wire) <input type="checkbox"/> N/A	3-Phase (4 wire) <input type="checkbox"/> N/A		Other <input type="checkbox"/> N/A	Prospective fault current $I_{pf}^{(2)}$	0.78	kA	N/A	
IT <input type="checkbox"/> N/A	Other <input type="text"/> N/A				External loop impedance $Z_e^{(2)}$	0.29	$\Omega$	Nominal current rating	LIM A
Confirmation of supply polarity <input checked="" type="checkbox"/>					Number of supplies	1		Short circuit capacity	N/A kA

(Note: (1) by enquiry, (2) by enquiry or by measurement)

**J. Particulars of Installation Referred to in the Report**

Means of earthing	Details of installation Earth Electrode (where applicable)		
Distributor's facility <input type="checkbox"/> N/A	Type (e.g. rod(s), tape etc.) <input type="checkbox"/> N/A	Location <input type="checkbox"/> N/A	
Installation earth electrode <input type="checkbox"/> N/A	Resistance to Earth <input type="checkbox"/> N/A $\Omega$	Method of measurement <input type="checkbox"/> N/A	

**Main Protective Conductors**

Tick boxes and enter details as applicable

Earthing Conductor	Material <input type="text"/> Copper	csa <input type="text"/> 16	mm <sup>2</sup>	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Main protective bonding conductors	Material <input type="text"/> Copper	csa <input type="text"/> 10	mm <sup>2</sup>	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>

**Bonding of Incoming Service**

Water installation pipes <input checked="" type="checkbox"/>	Gas installation pipes <input checked="" type="checkbox"/>	Structural Steel <input type="checkbox"/> N/A	Lightning protection <input type="checkbox"/> N/A	Maximum Demand (Load) <input type="text"/> 50 Amps
Oil installation pipes <input type="checkbox"/> N/A	Please State Other incoming service(s) <input type="text"/> N/A <input type="text"/> N/A			
				Protective measure(s) against electric shock <input type="text"/> ADS

**Main Switch / Switch-Fuse / Circuit-Breaker / RCD**

Location	<input type="text"/> GROUND FLOOR CLOAKROOM WC			Current rating	<input type="text"/> 100 A	<b>if RCD main switch</b> Rated residual operation current, $I_{\Delta n}$ <input type="text"/> N/A mA Rated time delay <input type="text"/> N/A ms RCD Operating time at, $I_{\Delta n}$ <input type="text"/> N/A ms
Type BS(EN)	<input type="text"/> 60947-3	No of poles	<input type="text"/> 2	Fuse/Device rating or setting	<input type="text"/> 100 A	
Supply Conductors material	<input type="text"/> Copper	Supply Conductors csa	<input type="text"/> 25 mm <sup>2</sup>	Voltage rating	<input type="text"/> 230 V	

**K. Observations**

Referring to the attached schedule(s) of Inspection and Test Results, and subject to the limitations specified at the Extent and Limitations of the Inspection and testing section.

No remedial action is required.  N/A The following observations are made

Item No	Observations	Code
1	PLEASE REFER TO THE REPORT FOR THE CONDITION OF THE INSTALLATION.	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

- C1 - Danger present. Risk of injury. Immediate remedial action required  0
- C2 - Potentially dangerous - urgent remedial action required  0
- C3 - Improvement recommended  1
- FI - Further investigation required without delay  0

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome		Comments	
<b>1.0</b>	<b>External condition of intake equipment (visual inspection only)</b>													
1.1	Service cable										✓		No	
1.2	Service head										✓		No	
1.3	Earthing arrangement										✓		No	
1.4	Meter tails										✓		No	
1.5	Metering equipment										✓		No	
1.6	Isolator (where present)										✓		No	
<b>2.0</b>	<b>Presence of adequate arrangements for other sources</b>													
2.1	Presence of alternative/additional supply warning notices at the origin of the installation										N/A		No	
<b>3.0</b>	<b>Earthing and bonding arrangements</b>													
3.1	Presence and condition of distributor's earthing arrangement										✓		No	
3.2	Presence and condition of earth electrode connection, where appropriate										N/A		No	
3.3	Confirmation of earthing conductor size										✓		No	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)										✓		No	
3.5	Confirmation of main protective bonding conductor sizes										✓		No	
3.6	Condition and accessibility of main protective bonding conductor connections										✓		No	
3.7	Condition and accessibility of other protective bonding connections										✓		No	
3.8	Provision of earthing and bonding labels at all appropriate locations										✓		No	
<b>4.0</b>	<b>Consumer unit(s)/ Distribution board(s)</b>													
4.1	Adequacy of working space/accessibility to consumer unit/ distribution board										✓		No	
4.2	Security of fixing										✓		No	
4.3	Condition of enclosure(s) in terms of IP rating										✓		No	
4.4	Condition of enclosure(s) in terms of fire rating										✓		No	
4.5	Enclosure not damaged/deteriorated so as to impair safety										✓		No	
4.6	Presence of linked main switch										✓		No	
4.7	Operation of main switch(es) (functional check)										✓		No	
4.8	Operation of main switch (functional), main switch capable of being secured in the OFF position										✓		No	
4.9	Manual operation of circuit breakers and RCDs to prove disconnection (functional check)										✓		No	
4.10	Correct identification of circuits and protective devices										✓		No	
<b>4.11</b>	<b>Presence of required charts and labels:</b>													
4.11.1	Provision of diagram, chart, table or equivalent forms of information										✓		No	
4.11.2	Warning notice of durable material indicating there are live parts which are not capable of being isolated by a single device										✓		No	
4.11.3	Periodic inspection notice positioned at or near the origin of the installation										✓		No	
4.11.4	Presence of RCD six-monthly test notice at or near consumer unit/distribution board										✓		No	
4.11.5	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit/distribution board										✓		No	
4.11.6	Presence of other required labelling provided										C3 (see section K)		No	
4.12	Compatibility of protective device(s), base(s) and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)										✓		No	
4.13	Single-pole switching or protective devices in the line conductors only										✓		No	
4.14	Protection against mechanical damage where cables enter consumer unit/ distribution board										✓		No	
4.15	Protection against electromagnetic effects where cables enter metallic consumer unit enclosure										✓		No	
4.16	RCDs provided for fault protection - includes RCBOs										✓		No	
4.17	RCDs provided for additional protection includes RCBOs										✓		No	
4.18	Confirmation of indication that SPD is functional										N/A		No	
4.19	Operation/adequacy of AFDD(s) where present										N/A		No	
4.20	Confirmation that conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure										✓		No	
4.21	Adequate arrangements where a generating set operates as a switched alternative to the public supply										✓		No	
4.22	Adequate arrangements where a generating set operates in parallel with the public supply										✓		No	

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome		Comments	
<b>5.0</b>	<b>Distribution/final circuits</b>													
5.1	Identification of conductors										✓		No	
5.2	Cables correctly supported throughout										C3 (see section K)		No	
5.3	Condition of insulation of live parts										✓		No	
5.4	Non-sheathed live conductors protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)										✓		No	
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation										✓		No	
5.6	Protective devices, type and rated current are suitable for fault protection										✓		No	
5.7	Presence and adequacy of circuit protective conductors										✓		No	
5.8	Co-ordination between conductors and overload protection devices										✓		No	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences										✓		No	
5.10	Cables adequately protected against mechanical damage and abrasion										✓		No	
<b>5.11</b>	<b>Provision of additional protection by 30 mA RCD for*:</b>													
5.11.1	- all socket-outlets with a rated current not exceeding 32 A										✓		No	
5.11.2	- mobile equipment not exceeding a rating of 32 A for use outdoors										✓		No	
5.11.3	- cables concealed in walls/partitions at a depth of less than 50 mm										✓		No	
5.11.4	- cables concealed in walls/partitions containing metal parts regardless of depth										N/A		No	
5.11.5	- all AC final circuits supplying luminaires within domestic household premises										✓		No	
<b>*Note: Older installations designed prior to BS 7671:2018 may not have been provided with RCDs for additional protection.</b>														
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects										✓		No	
5.13	Band II cables segregated/separated from Band I cables										✓		No	
5.14	Cables segregated/separated from communications cabling										✓		No	
5.15	Cables segregated/separated from non-electrical services										✓		No	
<b>5.16</b>	<b>Termination of cables at enclosures:</b>													
5.16.1	Connections soundly made and under no undue strain										✓		No	
5.16.2	No basic insulation of a conductor visible outside enclosure										✓		No	
5.16.3	Connection of live conductors adequately enclosed										✓		No	
5.16.4	Adequately connected at point of entry to enclosure										✓		No	
5.17	Condition of accessories including socket-outlets, switches and joint boxes is satisfactory										✓		No	
5.18	Suitability of accessories for external influences										✓		No	
5.19	Adequacy of working space/accessibility to equipment										✓		No	
5.20	Single-pole switching or protective devices in line conductors only										✓		No	
<b>6.0</b>	<b>Isolation and switching</b>													
<b>6.1</b>	<b>In general:</b>													
6.1.1	Presence and condition of appropriate devices										✓		No	
6.1.2	Correct operation verified										✓		No	
<b>6.2</b>	<b>For isolation and switching for mechanical maintenance only:</b>													
6.2.1	Capable of being secured in the OFF position where appropriate										✓		No	
6.2.2	Acceptable location (local/remote)										✓		No	
6.2.3	Clearly identified by position and/or durable marking(s)										✓		No	
<b>6.3</b>	<b>For isolation only:</b>													
6.3.1	Warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device										✓		No	
<b>7.0</b>	<b>Current-using equipment (permanently connected)</b>													
7.1	Condition of equipment in terms of IP rating										✓		No	
7.2	Equipment does not constitute a fire hazard										✓		No	
7.3	Enclosure not damaged/deteriorated so as to impair safety										✓		No	
7.4	Suitability for the environment and external influences										✓		No	
7.5	Security of fixing										✓		No	
7.6	Cable entry holes in ceiling above luminaires sized or sealed so as to restrict the spread of fire										✓		No	
	List number and location of luminaires inspected in section 9													



Board Details		TO BE COMPLETED IN EVERY CASE	ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
Location of Distribution Board	GROUND FLOOR CLOAKROOM WC	Supply to distribution board is from: N/A	Associated RCD (if any)
Distribution board designation	DB 1	No of phases: N/A      Nominal Voltage: N/A V	BS(EN): N/A
		Overcurrent protective device for the distribution circuit	RCD No of Poles: N/A
		Type BS(EN): N/A      Rating: N/A A	RCD Rating: N/A mA

Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times (s)	Overcurrent protective device					RCD	
					Live mm <sup>2</sup>	cpc mm <sup>2</sup>		BS(EN)	AFDD	Type	Rating (A)	Short circuit capacity (kA)	Operating current (Δn)	Maximum permitted Zs (Ω)
1/S	RCD Module (Split Board)	-	-	-	-	-	-	-	-	-	-	-	-	-
2/S	RCD Module (Split Board)	-	-	-	-	-	-	-	-	-	-	-	-	-
3/S	SHOWER	A	B	1	10	4	0.4	60898 MCB		B	40	6	30	0.87
4/S	COOKER	A	B	2	6	2.5	0.4	60898 MCB		B	32	6	30	1.09
5/S	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-
6/S	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-
7/S	CENTRAL HEATING	A	B	1	2.5	1.5	0.4	60898 MCB		B	16	6	30	2.18
8/S	FRONT ROOM SOCKETS	A	B	6	2.5	1.5	0.4	60898 MCB		B	16	6	30	2.18
9/S	LIGHTS	A	B	12	1.5	1	0.4	60898 MCB		B	6	6	30	5.82
10/S	RCD Module (Split Board)	-	-	-	-	-	-	-	-	-	-	-	-	-
11/S	RCD Module (Split Board)	-	-	-	-	-	-	-	-	-	-	-	-	-
12/S	KITCHEN SOCKETS	A	B	7	2.5	1.5	0.4	60898 MCB		B	32	6	30	1.09
13/S	1ST FLOOR SOCKETS	A	B	6	2.5	1.5	0.4	60898 MCB		B	16	6	30	2.18
14/S	GROUND FLOOR BEDROOM SOCKETS	A	B	3	2.5	1.5	0.4	60898 MCB		B	16	6	30	2.18
15/S	GROUND FLOOR BEDROOM LIGHTS	A	B	6	1	1	0.4	60898 MCB		B	6	6	30	5.82
16/S	SMOKE ALARMS	A	B	8	1.5	1	0.4	60898 MCB		B	6	6	30	5.82
17/S	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-
18/S	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code								
A	B	C	D	E	F	G	H	O
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic/SWA cables	Thermosetting/SWA cables	Mineral-insulated cables	Other

Board Tests

TO BE COMPLETED IN EVERY CASE		TEST INSTRUMENTS (SERIAL NUMBERS) USED	
Correct supply polarity confirmed <input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate) <input type="checkbox"/> N/A	Earth fault loop impedance <input type="text" value="101059631 PN"/>	RCD <input type="text" value="101059631 PN"/>
Supplementary Conductors <input checked="" type="checkbox"/>		Insulation resistance <input type="text" value="101059631 PN"/>	Multi-function <input type="text" value="N/A"/>
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION		Continuity <input type="text" value="101059631 PN"/>	Other <input type="text" value="N/A"/>
Zs <input type="text" value="N/A"/> Ω	lpf <input type="text" value="N/A"/> kA		
Operating times of associated RCD (if any) At IΔn <input type="text" value="N/A"/> ms			

Details of circuits and/or equipment vulnerable to damage

N/A

Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance					Polarity (✓)	Maximum measured earth fault loop impedance Ω	RCD			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Test Voltage	Live/Live MΩ	Live/Neutral MΩ	Live/Earth MΩ	Earth/Neutral MΩ			Disconnection time (ms)	Test button operation	AFDD Test button operation	
	r <sub>1</sub> (Line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	(R <sub>1</sub> + R <sub>2</sub> )	(R <sub>2</sub> )											
1/S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2/S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3/S	N/A	N/A	N/A	✓	N/A	500	N/A	LIM	11.3	10.2	✓	0.69	39.1	✓		NO
4/S	N/A	N/A	N/A	✓	N/A	500	N/A	22.4	11.2	10.2	✓	0.48	39.1	✓		NO
5/S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6/S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7/S	N/A	N/A	N/A	✓	N/A	500	N/A	LIM	11.2	10.2	✓	0.69	39.1	✓		NO
8/S	N/A	N/A	N/A	✓	N/A	500	N/A	LIM	10.9	10.2	✓	1.41	39.1	✓		NO
9/S	N/A	N/A	N/A	✓	N/A	500	N/A	LIM	10.4	10.2	✓	0.86	39.1	✓		NO
10/S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11/S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12/S	0.37	0.39	0.60	✓	N/A	500	N/A	LIM	100+	100+	✓	1.27	25.5	✓		NO
13/S	N/A	N/A	N/A	✓	N/A	500	N/A	LIM	100+	100+	✓	1.14	25.5	✓		NO
14/S	N/A	N/A	N/A	✓	N/A	500	N/A	LIM	100+	100+	✓	1.10	25.5	✓		NO
15/S	N/A	N/A	N/A	✓	N/A	500	N/A	LIM	100+	100+	✓	1.51	25.5	✓		NO
16/S	N/A	N/A	N/A	✓	N/A	500	N/A	LIM	100+	100+	✓	1.16	25.5	✓		NO
17/S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
18/S	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By

Signature <input type="text"/>	Position <input type="text" value="APPROVED ELECTRICIAN"/>
Name <input type="text" value="PAUL NORFOLK"/>	Date of testing <input type="text" value="08/06/2021"/>

**Extent of Electrical Installation covered by this report, Continued. from page 1**

APPROXIMATELY 30% OF ACCESSORIES WERE REMOVED FOR VISUAL INSPECTION.  
APPROXIMATELY 80% OF CIRCUIT TESTING WAS CARRIED OUT.  
APPROXIMATELY 90% OF ACCESSORIES HAVE BEEN VISUALLY INSPECTED.

**Agreed limitations including the reasons, Continued. from page 1**

THE WHOLE OF THE ABOVE PROPERTY WITH THE EXCEPTION OF THE OUTSIDE LIGHTING ,THE HEATING SYSTEM AND VENTILATION SYSTEMS.  
THE MAIN EXTERNAL LOOP READING HAS BEEN OBTAINED WITH THE MAIN EARTH CONDUCTOR STILL CONNECTED.  
THE INSTALLATION RESISTANCE TEST WERE CARRIED OUT BETWEEN LIVE AND NEUTRAL TO EARTH IN ACCORDANCE WITH GUIDANCE NOTE 3.

**General condition of the installations (In terms of electrical safety), Continued. from page 1**

THIS CERTIFICATE IS INVALID UNLESS ACCOMPANIED IN FULL BY THE ABOVE MENTIONED REPORT.  
FOLLOWING THE REMEDIAL WORK ALL CODE 1 & 2 DEFECTS FROM THE ABOVE REPORT HAVE BEEN CARRIED OUT.  
ALL CODE 3 DEFECTS STILL EXIST BUT ARE OF A LESS SERIOUS NATURE.