

Domestic Unvented Hot Water Storage Vessel Commissioning/Inspection Record



Electrical | Plumbing | Heating



Registered business		Job address		Landlord/agent				
Lindum Business Park Elvington York North Yorkshire YO41 4EP +44 1904608350		11 Danube House Darwin Close Huntington York North Yorkshire YO31 9PE		Simpson's Properties The Catalyst York Science Park Baird Lane, Heslington York North Yorkshire YO10 5GA +44 01904 911019				
Hot water storage vessel details								
Hot water storage vessel details				Heat source		Installing		Commissioning
Make	Model	Location	Indirect or Direct	Gas boiler and/or Solar, or Immersion heaters	Capacity (Ltrs)	Makers warning label attached	Inlet water pressure and flow rate	Fully commissioned
Tempest	120	Airing Cupboard	Direct	Immersion heater		Yes		Yes
Hot water storage vessel operating details			Discharge pipe work (D1)-Relief valve to tundish		Discharge pipework (D2)-Tundish to termination			
System operating pressure (Bar)	3	Nominal size of D1 (mm or inches)		Nominal size of D2 (mm or inches)				
Operating pressure of expansion vessel (Bar)		Length of D1 (mm)		Pipework material (copper/steel/plastic, etc)				
Operating pressure of expansion valve (Bar)	6	Number of discharges		Does pipework have a minimum vertical length of 300mm from tundish?				
Operating temperature of temperature relief valve (C)		Size of manifold, if more than one discharge						
Operating temperature and pressure of combined temperature and pressure relief valve (Bar/C)	7/ 90	Is tundish installed within the same location as the hot water storage vessel?		Yes	Does the pipework fall continuously to point of termination?			
		Is the tundish visible?		Yes	Method of termination (gully, low level, soil stack or high level)			
Maximum primary circuit pressure and flow temperature (indirectly heated vessel) (Bar/C)		Is automatic means of identifying discharge installed?		Yes	Method of termination satisfactory?		N/A	

Domestic Unvented Hot Water Storage Vessel Commissioning/Inspection Record (69)

Registered business :JDL Electrical, Plumbing & Heating Ltd

Registered business address :Lindum Business Park Elvington York North Yorkshire YO41 4EP

Observations		
Recommendations		
Engineer information	Received by information	Certificate information
Engineer name Ian Batt Signature 	Name Matthew Digby Received by Tenant Signature 	Date 2023-10-25 Number 69

Domestic Unvented Hot Water Storage Vessel Commissioning/Inspection Record (69)

Registered business :JDL Electrical, Plumbing & Heating Ltd

Registered business address :Lindum Business Park Elvington York North Yorkshire YO41 4EP