Landlord/Homeowner Gas Safety Record – CP12

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.





Registered Business	Site Address	<u>Landlord/Agent/Homeowner</u>
John Wright Electrical and Mechanical Services Ltd	23 Heslington Road	Simpson's Properties - Student Homes
Unit 1 Common Road		The Catalyst
Dunnington	York	York Science Park
York	North Yorkshire	York
North Yorkshire	YO10 5AR	North Yorkshire
YO19 5PD		YO10 5GA
01904 424114 Gas Safe Reg No: 501820		

No.	Location	Appliance Type	Make & Model	Flue type	Owned by Landlord	Appliance Inspected?
1	Airing Cupboard	Heat Only	Ideal Logic heat 18	RS	Yes	Yes
2						
3						
4						

No.	Operating pressure or heat input	Safety device(s) operating correctly	Ventilation satisfactory	Visual condition of flue & termination	Flue operation checks	Combustion analyser reading	Appliance Serviced?	Safe to use
1	18.96 mbar	Pass	N/A	Pass	Pass	0.0005	Yes	Yes
2								
3								
4								

No.	Defects Identified	Warning/Advice Notice Issued	Remedial Action Taken
1			
2			
3			
4			













Company No: 3449243



Head Office: Unit 1, Common Road, Dunnington, York YO19 5PD Tel: 01904 424114 www.johnwrightelectrical.co.uk

Page 1 | 2

Directors: M Smith, D Middleton & J Kirk

Landlord/Homeowner Gas Safety Record – CP12

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.





Certificate No. 454

Approved CO alarm	Yes	Gas installation pipework visual inspection	Yes	Comments
CO alarm in date	Yes	Number of appliances tested	1	
Tested CO alarm	Yes	Emergency control valve accessible	Yes	
Gas tightness test	Yes	Protective equipotential bonding satisfactory	Yes	

	Further Readings							
No.	со	CO ₂	O 2	CO / CO ₂ Ratio	Working pressure at meter	Working pressure at appliance	Flue gas temperature	Gas rate (if applicable)
1	46 ppm	8.6 %	5.7 %	0.0005	20.45 Mbar	18.96 Mbar	51 °C	
2								
3								
4								

Gas Engineer Details	Report Received By	Certificate Information
Name: Jake Sanderson	Received by: No person present	Certificate Number: 454
Gas Safe ID: 5759435	Name:	
		Date of certificate: 07/11/24
Signature:	Signature:	
		Next service due on or before:
		07/11/25
11/2 / =		07/11/23
M		
-		













Company No: 3449243



Page 2 | 2

Directors: M Smith, D Middleton & J Kirk